



**SECTION A-A**

**NOTES:**

1. UNDERGROUND CONDUIT ENDS SHALL BE CAPPED WITH A GALVANIZED THREADED CONDUIT PLUG UNLESS CONNECTED TO AN EXISTING CONDUIT.
2. PLACE 2 EACH 6" (150) x 1/2" (13) P.V.C., SCHEDULE 40 (TYP) VENTS IN THE GROUT AS DIRECTED IN THE FIELD BY THE ENGINEER.

**PLAN SYMBOL**

○  
(SAME AS NORMAL POLE BASE)



DELAWARE  
DEPARTMENT OF TRANSPORTATION

**SPECIAL POLE BASE**

STANDARD NO. T-6 (2002)

SHT. 1 OF 1

APPROVED *Caution Wicks* 9/6/02  
CHIEF ENGINEER DATE  
RECOMMENDED *Therese Roberts* 8/19/02  
DESIGN ENGINEER DATE