



SECTION A-A

NOTES:

1. UNDERGROUND CONDUIT ENDS SHALL BE CAPPED WITH A GALVANIZED THREADED CONDUIT PLUG UNLESS CONNECTED TO AN EXISTING CONDUIT.
2. PLACE 2 EACH 6" (150) x 1/2" (13) P.V.C., SCHEDULE 40 (TYP) VENTS IN THE GROUT AS DIRECTED IN THE FIELD BY THE ENGINEER.



DELAWARE
DEPARTMENT OF TRANSPORTATION

SPECIAL POLE BASE

STANDARD NO. T-6 (2005) SHT. 1 OF 1

APPROVED *Carolann Wick* 12/15/05
CHIEF ENGINEER DATE
RECOMMENDED *James M. O'Brien* 11/29/05
DESIGN ENGINEER DATE