




TYPICAL SECTION (BASES 5 AND 6)

NOTE:
SEE SPECIFICATIONS AND DETAILS FROM CURRENT PURCHASING CONTRACT FOR ANCHOR BOLT DIMENSIONS.

POLE BASE DATA CHART				
POLE BASE TYPE #	DIAMETER	DEPTH *	#4 (#13) HORIZONTAL REINFORCING BARS	#8 (#25) VERTICAL REINFORCING BARS
1	36" (915)	7' (2150)	5	8
2	36" (915)	10' (3050)	6	8
2A	48" (1220)	8' (2450)	5	8
2B	60" (1525)	7' (2150)	5	8
3	48" (1220)	10' (3050)	6	8
3A	60" (1525)	9' (2750)	6	8
3B	72" (1830)	7' (2150)	5	8
4	24" (610)	2'-4" (725)	NONE	NONE
5	36" (915)	4' (1225)	NONE	NONE
6	24" (610)	6' (1850)	4	8
7	48" (1220)	13'-4" (4000)	7	8

* - ADDITIONAL DEPTH FOR POLE BASE EXTENSION, IF REQUIRED, TO BE DETERMINED BY TRAFFIC ENGINEERING AND MANAGEMENT (TEAM) FIELD REPRESENTATIVE.

 DELAWARE DEPARTMENT OF TRANSPORTATION	POLE BASES			APPROVED  <small>CHIEF ENGINEER</small>	11/18/08 <small>DATE</small>
	STANDARD NO. T-5 (2008)	SHT. 3	OF 3	RECOMMENDED  <small>DESIGN ENGINEER</small>	11/17/08 <small>DATE</small>