



CURB / SIDEWALK OPENING

- NOTE:**
- 1). WHEN A GRASS STRIP IS PRESENT BETWEEN THE BACK OF CURB AND SIDEWALK, THE SIDEWALK PORTION OF THIS STRUCTURE MAY BE PRECAST. HOWEVER, WHEN THE SIDEWALK IS DIRECTLY BEHIND THE CURB, THE ENTIRE UNIT MUST BE CAST-IN-PLACE.
 - 2). SIDEWALK WIDTHS LESS THAN SHOWN ON THIS SHEET REQUIRE DEPARTMENT APPROVAL. SEE PEDESTRIAN ACCESSIBILITY STANDARDS MANUAL FOR MORE GUIDANCE.
 - 3). THE SLAB WIDTH OVER THE CONCRETE SPILLWAY SHALL BE 12" WIDER THAN THE SIDEWALK WIDTH ON THE APPROACH TO THE CURB OPENING