

**Supplemental Specifications to the August 2001 Standard Specifications**  
**(Revised January 3, 2008)**

**\*\*\* Note: Modifications to the Supplemental Specifications under this Revision have been highlighted in gray for easy identification.\*\*\***

**Subsection 101.78 Subcontractor. (3/18/2004)**

Modify the second paragraph as follows:

Exceptions to this definition are suppliers limited to delivering and depositing, but not incorporating material, suppliers of services that transport material, and the work performed which does not advance the completion of the Contract and is not considered as an item of work.

**Subsection 101.79 Substantial Completion. (3/18/2004)**

Modify the sentence as follows:

The point at which all Contract items are complete as deemed by the Department excluding any warranties or vegetation growth.

**Subsection 102.07 Irregular Proposals. (5/15/2006)**

Modify Paragraph B. as follows:

B. There are unauthorized additions, interlineations, conditional bids, or irregularities of any kind that may tend to make the proposal incomplete, indefinite, or ambiguous.

Delete paragraph G.

Modify Paragraph I. as follows:

I. The Contractor fails to provide a proposal guaranty.

**Subsection 104.04 Accident Notification. (5/15/2006)**

Modify the paragraph as follows:

Notify the Transportation Management Center (T.M.C.) at 659-2400 and Engineer concerning any accidents.

**Subsection 105.04 Plans and Working Drawings. (5/15/2006)**

Modify the 4<sup>th</sup> paragraph as follows:

Working drawings for concrete structures shall provide such details as are required for successful prosecution of the work. These shall include plans for items

such as falsework, bracing, sheeting, shoring, cofferdams, formwork, masonry layout diagrams and bending diagrams for reinforcing steel.

**Subsection 105.06 Coordination of the Plans, Standard Specifications, Supplemental Specifications, and Special Provisions. (1/3/2008)**

Modify and renumber the following:

1. General Notices (Including Pre-bid meeting minutes & Pre-bid Questions and Answers)
2. Pay Units in Bid Proposal Forms
3. Plans
4. Cross Sections
5. Special Provisions
6. Supplemental Specifications
7. Standard Construction Details
8. Standard Specifications

**Subsection 105.09 Utilities. (1/3/2008)**

Add the following paragraph:

Overhead High-Voltage Line Safety requires notification to and mutually agreeable measures from the utility from any person intending to carry on any function, activity, work or operation within 10' of any high voltage overhead line.

**Subsection 105.13 Maintenance During Construction. (3/18/2004)**

Add the following:

The contractor shall mow all grass and weeds within the limits of the Contract, as directed by the Engineer, up to 4 times a year to a height in compliance with subsection 107.01.

**Subsection 105.20 Project Acceptance. (3/18/2004)**

Modify the first paragraph as follows:

Final acceptance will not occur until completion of the Project in accordance with Subsection 101.16. The Contract time will be stopped at substantial completion.

**Subsection 106.09 Disposal of Unacceptable Materials. (5/15/2006)**

Modify the paragraph as follows:

All waste materials removed by earthwork operations shall become the property of the Contractor and shall be removed from the Project or otherwise disposed of as specified. Unless specific disposal sites are designated on the Plans, the Contractor shall procure disposal sites. Such disposal sites shall be submitted to and approved by the Engineer. If the contract is federally funded or Federally permitted, the Engineer will submit the proposed site to the State Historic Preservation Office for their approval prior

to utilization by the Contractor. No areas that are designated as wetlands will be permitted for use as disposal sites. The submittal shall include a plan of the disposal area, proposed sediment and erosion control devices, existing and proposed final contours, and proposed security measures. All permit requirements such as those required by the Department of Natural Resources and Environmental Control (DNREC) and the U.S. Army Corps of Engineers shall be met by the Contractor when preparing and utilizing off-site disposal areas. The Contractor shall submit a similar proposal for use of designated disposal sites if such detail is not included in the Contract documents. Costs for preparing these plans are incidental to [Section 201](#). For disposal sites designated on the Plans, payment will be made separately under applicable bid items for all necessary erosion and sediment controls, seeding, and mulching. For Contractor-procured disposal sites, such costs are incidental to [Section 201](#). The Department will not consider any delays or monetary claims of any nature resulting from the Contractor's failure or difficulty in finding the necessary disposal sites.

**Subsection 107.04 Contractor's Responsibility for Utility Property and Services. (5/15/2006)**

Modify the 3<sup>rd</sup> paragraph as follows:

Fire hydrants on or adjacent to the highway shall be kept accessible to fire apparatus at all times and no material or obstruction shall be placed within 15' (4.5 m) of any such hydrant. Work shall be left entirely accessible at all points to fire apparatus at all times. Whenever any work is done in the area of a fire hydrant or whenever a fire hydrant is relocated or installed, the center of the hose outlet shall be a minimum of 18 in. (457 mm) above the final grade directly beneath the hose outlet.

**Subsection 107.07 Public Convenience and Safety. (1/3/2008)**

Add the following paragraph:

The Contractor shall maintain a safe work site at all times and be prepared to make repairs as needed after normal working hours in the case of an emergency. If the Department is unable to contact the Contractor to make these repairs then State Maintenance forces or a third party contractor may be used to make such repairs. The cost for this work shall be calculated according to Subsection 109.04(D) for all state personnel involved or third party contractor, including vehicles, equipment and materials needed. This cost will be deducted from money due the Contractor under the Contract.

**Subsection 107.09 Protection and Restoration of Property. (5/15/2006)**

Modify the 4<sup>th</sup> sentence in the first paragraph as follows:

The Contractor shall not injure or destroy trees or shrubs outside the limits of construction, nor remove or cut them without proper authority.

**Subsection 108.01 Subletting of Contract. (3/18/2004)**

Modify the second paragraph as follows:

If the Contractor to whom a contract is awarded proposes to subcontract any part of the work, the scope and value of the work to be done by the subcontractor shall be

outlined. The cost of materials to be used by the subcontractor shall be outlined. The cost of materials to be used by the subcontractor shall be included in the value of the subcontracted work. A subcontractor shall not subcontract further a portion of the work intended to be done by the original subcontractor without the express written permission of the Engineer. In granting such permission, the Engineer shall ensure that the subcontractor seeking to subcontract the work to be performed by another shall nonetheless perform with its own organization work amounting to not less than 50% of the total subcontracted bid price.

**Subsection 108.09 Schedule of Liquidated Damages. (5/15/2006)**

Update table with these new numbers.

**Schedule of Liquidated Damages**

Awarded Contract Value		Daily Charge	
For More Than –	To and Including –	Work Day	Calendar Day
\$ 0	\$ 25,000	\$ 380.00	\$ 275.00
25,000	50,000	400.00	290.00
50,000	100,000	540.00	390.00
100,000	500,000	840.00	600.00
500,000	1,000,000	1,090.00	780.00
1,000,000	2,000,000	1,350.00	960.00
2,000,000	5,000,000	1,410.00	1,010.00
5,000,000	10,000,000	1,590.00	1,130.00
10,000,000	15,000,000	2,510.00	1,790.00
15,000,000	20,000,000	4,180.00	2,990.00
20,000,000	25,000,000	5,850.00	4,180.00
25,000,000	30,000,000	7,520.00	5,370.00
30,000,000	35,000,000	9,190.00	6,570.00
35,000,000	Over	10,870.00	7,760.00

**Subsection 109.01 – Measurement of Quantities. (1/3/2008)**

Add the following sentence to Paragraph A:

A. Weight tickets shall be computer generated.

**Subsection 109.04 Payment for Differing Site Conditions, Major Changes, Extra Work, and Force Account. D.8. Subcontracting. (5/15/2006)**

Modify the paragraph as follows:

Should an agreed price involve work to be performed by a Subcontractor, then the Prime Contractor's total allowable mark-up on the Subcontracted portion of work shall not exceed 10% of the Subcontractor's proposed price. The Prime Contractor

shall, upon request by the Department, submit documentation substantiating the Subcontractor's proposed price.

## **Section 110 - Erosion, Sediment Control and Water Pollution (1/3/2008)**

Delete Section 110 in its entirety modify as follows:

- 110.01** Definitions
- 110.02** Legal Authority
- 110.03** Sediment and Stormwater Permit Approval
- 110.04** Description of Work
- 110.05** Completion of the Work
- 110.06** Plan Changes
- 110.07** Limits of Construction
- 110.08** Division of Responsibilities
- 110.09** Vegetative Stabilization
- 110.10** Temporarily Stockpiled Material
- 110.11** Channel and Ditch Scour Protection
- 110.12** Sediment-Laden Runoff
- 110.13** Dewatering Operations
- 110.14** Clean Water Diversions
- 110.15** Stream Diversions
- 110.16** Temporary Stream Crossings
- 110.17** Wash Water
- 110.18** Waste Water
- 110.19** Water Pollution Violations Enforced
- 110.20** Maintenance
- 110.21** Erosion and Sediment Control Reports
- 110.22** Failure to Implement and Maintain Erosion and Sediment Control Measures
- 110.23** Contractor Payment
- 110.24** Fines Resulting from Non-Compliance

### **110.01 Definitions.**

*Clearing.* The clearing of trees, brush, shrubs, downed timber, rotten wood, rubbish, and any other vegetation, except where excluded by the definition for grubbing, as well as the removal of fences and structures. See Subsection 201.01.

*Disturbed Area.* An area where any activity has been initiated which may result in soil erosion from water or wind or movement of sediments or pollutants into state waters or onto lands in the state, or which may result in accelerated stormwater runoff, including, but not limited to, clearing, grubbing, grading, excavating, transporting, filling, and backfilling of land.

*Grubbing.* Shall mean the removal of trees, stumps, roots, brush, root mat, and debris from the ground.

*Limited Suspension of Activity.* Suspension of specific land disturbing work activities when the Contractor fails to implement and maintain the erosion and sediment controls after verbal or written direction to do so by the Engineer. This suspension would be specific to the land disturbing activities that are not compliant. During a Limited Suspension of Activity, progress payments for these specific activities will be withheld

until the Contractor has corrected the problems. Time charges will continue and no claim for delay will be considered during a Limited Suspension of Activity.

*Phasing.* Staged construction sequencing as shown in the Plans.

*Significant Rain Event.* A rain event that generates erosion.

*Site Reviewer.* A person on the Contractor's staff assigned to erosion and sediment control review, implementation and maintenance. The level of training (Contractor's Certification or Certified Construction Reviewer) required for the Site Reviewer will be noted in the project plans.

A. *Contractor's Certification (Blue Card).* Introductory training for erosion and sediment control provided by the Department of Natural Resources (DNREC). For projects designated as having Minor erosion potential, the Contractor must submit as part of his bid, the name and certification number for someone other than the Superintendent who has a Blue Card certification.

B. *Certified Construction Reviewer (CCR, Gold Card).* Advanced training for erosion and sediment control provided by the Department of Natural Resources (DNREC). For projects designated as having Medium or Major erosion potential, the Contractor must submit as part of his bid the name(s) and certification number(s) for the individuals on his staff who have a CCR (Gold Card) certification as noted on the plans.

**110.02 Legal Authority.** The Department is a delegated agency of DNREC as defined in Chapter 40, Title 7 of the Delaware Code and the Delaware Sediment and Stormwater Regulations. Any project built by Contract with the Department shall maintain compliance with the aforementioned law and regulations at all times throughout the life of that project. As a delegated agency, the Department shall enforce compliance with the law and regulations through the Contract documents or may refer a violation to DNREC for enforcement action.

**110.03 Sediment and Stormwater Permit Approval.** A signature, date, and seal in the Stormwater Engineer's block on the title sheet of the Plans indicates that the Plans were designed in conformance with the applicable State and Federal stormwater regulations and that the Sediment and Stormwater Permit is approved. All work shall be completed pursuant to the Plans and as directed by the site reviewer and the Stormwater Engineer.

Neither review and approval of the erosion, sediment control, and water pollution control plans nor errors and omissions in the plans shall relieve the Contractor from its responsibilities for compliance with the Delaware Sediment and Stormwater Regulations or other applicable laws or regulations and the more stringent water pollution control requirements shall apply.

**110.04 Description of Work.** Erosion and sediment control measures shall be applied to erodible earth material exposed by any of the Contractor's land disturbing activities on the Project. The work shall consist of the application of temporary and permanent erosion and sediment control items as provided in the Contract or ordered by the Site Reviewer or the Engineer. The temporary erosion control items shall be coordinated with the permanent erosion control items specified. The items shall include, but are not limited to, the use of berms, dikes, dams, sediment basins, traps, geotextiles, stone check dams, silt fences, phased construction, special land grading methods, mats and nets, aggregates, mulches, grasses, slope drains, chemical binders, tackifiers, and other erosion and sediment control items or approved methods as designated in the Contract documents or as directed by the Site Reviewer or the Engineer.

**110.05 Completion of the Work.** The Contractor shall implement the temporary and permanent erosion control items for each phase of construction as detailed in the Contract documents. Additional erosion and sediment control items may be required during the Project as deemed necessary by the Site Reviewer and the Engineer in order to provide continuous erosion and sediment control protection.

Before starting each phase of any land-disturbing activity, the Site Reviewer shall make certain that all erosion and sediment control items required in that phase are properly installed and functional.

**A. Construction Phasing.** For Project sites in excess of 20 ac (8 ha), the construction must be phased in 20 ac (8 ha) increments. Once grading is initiated in one 20 ac (8 ha) increment, a second 20 ac (8 ha) increment may be cleared and grubbed provided the Contractor installs and maintains effective erosion and sediment control measures on both sections in such quantities and locations as deemed acceptable by the Site Reviewer and the Engineer.

When balancing earthwork, such as when borrow from a cut is used as fill at a noncontiguous location distant from the cut, more than a total of 20 ac (8 ha) may be allowed to be grubbed and graded within the overall limits of the Project at any one time with prior written approval from the Engineer. In such cases, one 20 ac (8 ha) increment in cut and one 20 ac (8 ha) increment in fill may be grubbed and graded at each separate location concurrently. Examples of when this would likely occur would be on interchange construction or on a new alignment.

The Site Reviewer or the Engineer may further limit the area of clearing, grubbing, stripping, and grading operations to the Contractor's capability and actual progress of keeping the finish grading, mulching, seeding, and other temporary or permanent erosion control measures current according to the approved progress schedule and construction sequence.

**B. Construction Sequence.** The Contractor shall sequence the construction to comply with the following constraints unless indicated otherwise on the Plans:

1. Implement temporary erosion and sediment control items prior to any operation, which exposes soil to erosion, such as during the clearing portion, and prior to the grubbing portion of each phase of construction.
2. Schedule and perform the clearing and grubbing operations so that grading operations and permanent stabilization can follow immediately thereafter. Once earthwork has begun, the operation shall be continuous from clearing and grubbing through to completion of grading and final stabilization in accordance with Subsection 110.09 A.2. Any interruption in these operations in excess of 14 calendar days must be approved by the Engineer and shall require interim stabilization in accordance with Subsection 110.09 A.1.
3. Vegetatively stabilize bare soil areas in each phase of construction in accordance with Subsection 110.09 A.1 prior to advancing the work into the next phase of construction.
4. Vegetatively stabilize all cut and fill slopes of the highway excavation and embankment as the work progresses in height increments not to exceed 4' (1.2 m) of embankment. This will minimize exposed soil on the slopes to bands of 9-12 feet as measured along the slope face.

Excavate roadside ditches as early in the Project as possible to establish good drainage.

5. Vegetatively stabilize all grass ditches, swales, and medians within seven calendar days after their initial excavation.
6. Remove temporary erosion and sediment controls after final stabilization is complete in accordance with Subsection 110.09 A.2. Return land contours to original grade or as indicated on the Plans, and vegetatively stabilize any remaining bare soil areas.

**110.06 Plan Changes.** The Contractor shall not deviate from the erosion, sediment control, and stormwater management aspects of the Contract shown in the Plans and contract documents, other than as specified in 110.08.A.2.b without prior review and approval by the Engineer, the Stormwater Engineer, the Department's Environmental Section and appropriate regulatory authorities.

For plan changes initiated by the Contractor, revised construction Plans shall be submitted for review and approval by the Engineer, the Stormwater Engineer, the Department's Environmental Section and appropriate regulatory authorities. The revised Plans shall be prepared in accordance with current Department standards for roadway design, traffic control, erosion and sediment control, and stormwater management. Revised Plans shall also conform to all applicable Federal, State, or municipal pollution control laws, rules, or regulations. All supporting design calculations and cost analyses required by the Engineer shall accompany the submission. The number of copies required to be submitted for review shall be determined by the Engineer depending on the nature of the proposed revision.

Contractor proposed revisions to the Plans, as well as review time by the Department, will not justify a delay in the progress schedule. All costs involved in preparing plan revision documents for changes proposed by the Contractor shall be the responsibility of the Contractor.

**110.07 Limits of Construction.** The Contractor shall not perform any work including, but not limited to, clearing, grubbing, construction phasing, equipment storage, and material stockpiling outside the limits of construction shown on the Plans without prior approval of the Engineer.

If the Contractor should require additional lands that are not within Department rights-of-way or easements, it shall be the Contractor's responsibility to make all arrangements with the property owners and to acquire all permits from the appropriate regulatory authorities for the use of these lands.

The Contractor shall acquire a statement signed by the property owners, which releases the Department from all claims arising from the use of the property being considered. The signed statement from the property owner and copies of all permits acquired by the Contractor shall be transmitted by the Contractor to the Engineer for the Engineer's records prior to initiating any operation on the property being considered for use.

#### **110.08 Division of Responsibilities.**

A. *Site Reviewer.* The Site Reviewer is responsible for the following:

1. On Projects with Erosion Potential identified as Minor, Medium, or Major:
  - a. The Site Reviewer shall review and become familiar with all elements of the approved sediment and stormwater

management plan. Any questions or issues raised during this review should be discussed with the Contractor, Designer and the Department at the pre-construction meeting. The Site Reviewer should bring up any questions about the plans at this meeting.

- b. The Site Reviewer shall inspect all perimeter controls in accordance with the approved plan and the Department's Standard Construction Details for Erosion and Sediment Control prior to the Contractor beginning any earth disturbing activities and shall submit an Erosion and Sediment Control Report (E & S Report) to the Department stating that all perimeter controls are in place and functioning.
- c. The Site Reviewer shall perform sediment and stormwater reviews of the site jointly with a member of DeIDOT's construction inspection staff. These inspections shall be completed at least weekly and immediately after any significant rain event. The Site Reviewer shall prepare an E & S Report, which details any corrective actions that need to be implemented and a completion date for each. If no deficiencies exist, the report shall document that all erosion and sediment control measures are in place and functioning. The Site Reviewer and the Inspector shall sign and date the E & S Report at the conclusion of the field inspection. By close of business that day, the report shall be forwarded, via email or FAX, to the Contractor's Superintendent for Implementation with copies sent to the Department's Construction Engineer, the Project Resident, the Stormwater Engineer, and the Contractor's engineer.
- d. With concurrence of the Engineer, once all land disturbing activities are completed and all permanent erosion and sediment controls and stormwater management elements are in place and vegetatively stabilized, the Site Reviewer shall contact the Stormwater Engineer and schedule an as-built inspection of these features.

2. On Projects with Erosion Potential identified as Medium and Major the Site Reviewer shall be responsible for all of the requirements under 110.08A.1. plus the following (Site Reviewer must be a CCR):

- a. The Site Reviewer shall accurately fill out a Stormwater Management Facility Construction Checklist(s) for permanent stormwater management ponds. The Site Reviewer shall be present during the construction of these facilities to observe all checklist items for compliance with approved plans and applicable pond construction codes.
- b. The Site Reviewer with concurrence of the DeIDOT Project Resident may approve minor changes or deviations to the approved erosion and sediment control/ stormwater management plan. Changes, so approved, shall be documented in the Site Reviewer's weekly report.

**B. Contractor's Professional Engineer.** The Contractor's Professional Engineer is responsible for the following:

1. The Contractor's PE shall supervise the Site Reviewer and assure that he or she is performing all of his or her duties and completing all reporting requirements within the timeframes identified in this specification.
2. The Contractor's Professional Engineer shall review, sign and date all E & S Reports that proposed corrective actions that will require plan revisions.
3. The Contractor's Professional Engineer shall sign and seal any Plan Revisions the Contractor proposes to the stormwater management plan, the construction phasing, or the erosion and sediment control plans.
4. The Contractor's Professional Engineer shall review, sign and seal the Stormwater Management Facility Construction Checklist after the Site Reviewer has filled it out

**C. Engineer.** The Engineer is responsible for the following:

1. The Engineer is responsible for ensuring that all work is completed in accordance with the approved erosion and sediment control/ stormwater management plan. The Engineer shall designate an E&S inspector on each project who shall accompany the Site Reviewer on site inspections.
2. The Engineer is responsible for assuring the contractor is providing a Site Reviewer if required by the General Notes of the construction plans. The Engineer is also responsible for referring to the Stormwater Engineer any Site Reviewer who fails to perform the duties assigned by this Contract.

**D. Stormwater Engineer.** The Department's Stormwater Engineer is responsible for the following:

1. The Stormwater Engineer or his designee shall be represented at the pre-construction meeting and at any erosion and sediment control specific meetings. Any concerns about plan implementation or general procedures shall be discussed and resolved at these meetings.
2. In accordance with subsection 110.22, when the Site Reviewer refers a site or if the condition of the site is consistently not improved by the dates noted in the weekly reports the Stormwater Engineer shall recommend that the Engineer pursue enforcement actions to gain compliance. A Site Reviewer may refer a site for failure to implement the approved erosion and sediment control/ stormwater management plan, or for failure to comply with the recommendations in the E & S Reports.
3. The Stormwater Engineer or his designee shall perform annual performance evaluations of the Site Reviewers using the Department's evaluation form. If it is determined that a Site Reviewer is not providing adequate site control or is not referring problem situations, the representative shall require the Contractor to replace the Site Reviewer for the Project and request that DNREC suspend or revoke his/her certification.
4. The Stormwater Engineer or his designee shall perform an as-built inspection of the permanent erosion and sediment controls and Stormwater management features to determine compliance with the approved Sediment and Stormwater Management Plan. If the Stormwater Engineer or his designee identifies deficiencies during the

inspection, a letter will be issued to the Project Resident who will notify the Contractor. These deficiencies must be satisfactorily corrected prior to project closeout.

5. The Stormwater Engineer shall complete the Notice of Intent (NOI) at the start of the project and the Notice of Termination (NOT) at the end of the project to meet the requirements of the NPDES Permit.

### **110.09 Vegetative Stabilization.**

A. *Interim and Final Stabilization.* An area of the work shall be considered vegetatively stabilized for erosion control if it meets the criteria in one of the following two cases:

1. *Interim Stabilization.* The seeding and mulching items, sod, or erosion and sediment control items as noted on the Plans are in place and accepted by the Engineer.
2. *Final Stabilization.* Meets the requirement for the removal of the temporary erosion controls placed during interim stabilization, and has complete vegetation growth in accordance with section 734 as determined by the Engineer. Complete growth of vegetation includes permanent grass reaching a height of 3" (75 mm) over all seeded areas.

B. *Incremental Stabilization.* Side slopes, and other slopes 1:3 (vertical to horizontal) or steeper require placement of either temporary or permanent seeding and mulching as the work progresses in height increments not to exceed 4' (1.2 m) of embankment. This will minimize exposed soil on the slopes to bands of 9-12 feet as measured along the slope face.

C. *Tracking of Slopes.* During grading operations the Contractor shall track all slopes 1:3 (vertical to horizontal) or steeper to prevent gully and sheet erosion. The tracking shall be accomplished by driving cleated equipment such as a bulldozer up and down the slopes so the cleats make horizontally oriented indentations in the soil. All costs associated with tracking of slopes at regular increments shall be incidental to Section 202.

Prior to applying seeding items on slopes 1:3 (vertical to horizontal) or steeper, the Contractor shall track the slopes as described above in order to prepare a stable seedbed. All costs associated with tracking of slopes to prepare a seedbed shall be incidental to the topsoil item being applied to the slope surface.

D. *Maximum Soil Exposure Times.* All erodible earth material exposed by the Contractor's activities shall be vegetatively stabilized within the time frames specified below:

<u>Location</u>	<u>Maximum Time to Vegetatively Stabilize</u>
Sediment controls	Seven calendar days from initial construction (berms, ditches, traps, basins, etc.)
Areas meeting final grades	Seven calendar days from completion of grading
Areas not meeting final grades	Fourteen calendar days from ceasing work in that location

**110.10 Temporarily Stockpiled Material.** Erodible earth material designated on the Plans or required by the Engineer to be excavated and temporarily stockpiled for later use in the Project shall be located away from live streams and wetlands and placed only in areas deemed appropriate by the Engineer.

The Contractor shall install the erosion and sediment control items designated on the Plans or as directed by the Site Reviewer and the Engineer about the base of the pile in advance of the actual stockpiling operation. Erodible earth material shall be placed in piles of neat conformations. Side slopes shall be seeded and mulched as the pile is placed. All remaining unstabilized surfaces shall be seeded and mulched immediately following completion of the stockpiling operation.

If the Contractor proposes to stockpile erodible earth material in areas not designated on the Plans, it shall be the Contractor's responsibility to prepare and submit erosion and sediment control plans for those proposed areas, which are located within Department rights-of-way and easements for approval by the Site Reviewer and the Engineer. Materials shall not be stockpiled until an erosion and sediment control plan for the proposed stockpile has been approved by the Site Reviewer and the Engineer. The Contractor is also responsible for getting any permits that are necessary.

If the Contractor proposes to stockpile erodible earth material in areas outside of Department rights-of-way and easements, it shall be the Contractor's responsibility to prepare and submit for approval a plan for the use of the proposed site to the appropriate agencies having jurisdiction. No stockpiling operation shall commence in areas outside the Department rights-of-way and easements until the Engineer has received copies of all plans and permits approved by the appropriate regulatory agencies and received copies of statements signed by the property owners, as required under Subsection 110.07, which release the Department from any claims arising from the use of the property. The Contractor shall be responsible for all costs associated with the installation of erosion and sediment controls required by other agencies having jurisdiction on stockpiles located outside the Department's rights-of-way.

**110.11 Channel and Ditch Scour Protection.** Riprap or other proposed channel lining items designated on the Plans at pipe, culvert, and bridge inlets and outlets and along channel lengths shall be placed before the pipes, culverts, bridges, and channels become operational.

**110.12 Sediment-Laden Runoff.** Stormwater runoff from disturbed areas shall be directed to an approved sediment control measure, such as a trap or basin, prior to release to ditches, storm drain systems, streams, or surface water bodies of any type. All storm drain pipes, which convey sediment-laden runoff, shall discharge to a sediment trap or sediment basin prior to release from the Project limits of construction as shown on the Plans, or as directed by the Site Reviewer and the Engineer.

**110.13 Dewatering Operations.** The Contractor shall not pump or otherwise withdraw water from below the water table at a rate exceeding 50,000 gallons (189 270 L) per day without having first obtained the necessary water allocation and well permits.

The Contractor is responsible for obtaining all permits required from the appropriate issuing authority for the withdrawal of groundwater from the Project site. Costs associated with water allocation and water well permit acquisition shall be paid by the Contractor. The Contractor shall submit copies of all permit approvals to the Engineer for the Engineer's records.

Sediment-laden dewatering discharge shall be directed to an approved sediment trapping device such as a dewatering basin, portable sediment tank, sediment trap, or sediment basin, prior to release to ditches, storm drain systems, streams, or surface water bodies of any type.

Prior to initiating a pumping operation to remove water from open excavations or temporary cofferdams, the area to be dewatered shall be allowed to rest undisturbed under quiescent conditions for a period of 12 hours in order to induce physical settling of suspended particles.

The Contractor shall attach the suction line of the pumping equipment to a flotation device, immersing the intake end no more than 6" (150 mm) below the water surface. In this manner, water shall be "skimmed" off the surface. Once the water level has been pumped down, further dewatering shall be accomplished in conjunction with a sump pit constructed in conformance with Department standards or as directed by the Engineer.

**110.14 Clean Water Diversions.** Stormwater runoff from non-disturbed areas shall be directed away from work areas using any combination of berms, pipes, dikes, swales, pumps and slope drains or as shown on the Plans, or as directed by the Site reviewer and the Engineer.

**110.15 Stream Diversions.** The Contractor shall not conduct work in a stream without having first obtained the appropriate wetland and subaqueous lands permit(s).

When work is to be conducted in the flow line of a stream, whether the stream is perennial or intermittent, the Contractor shall use any combination of dikes, swales, ditches, cofferdams, pipes, pumps, and other devices as shown on the Plans, or as directed by the Engineer to direct the stream flow around the work area.

**110.16 Temporary Stream Crossings.** Equipment shall not be operated in live streams without a stream diversion being installed to the satisfaction of the Engineer. Temporary bridges or other structures shall be installed if the work requires the crossing of a stream by construction equipment.

**110.17 Wash Water.** Water containing sediment from any construction activity on the Project such as truck washing, saw cutting, milling, aggregate washing, and equipment washing and which is not regulated as a waste water under State or Federal statutes shall be discharged to a sediment trapping device and treated by filtration or settling. Sediment-laden wash water shall not be discharged directly to any ditches, storm drain systems, streams, or surface water bodies of any type. Water mixed with Bentonite (a natural material formed from clay particles) used for drilling or augering shall be collected and removed appropriately. An appropriate use may be disposal in approved fill areas of the project.

**110.18 Waste Water.** Water containing pollutants such as raw sewage, bitumens, fuels, lubricants, paint, or other harmful materials, is strictly regulated under State and Federal statutes and as such shall not be discharged into waters of the State as defined in Chapter 60, Title 7 of the Delaware Code or into natural or manmade channels or storm drain systems leading to waters of the State.

The Contractor is responsible for obtaining all permits required from the appropriate issuing authority for the discharge of waste waters from the Project site. The Contractor shall pay costs associated with waste water permit acquisition. The

Contractor shall submit copies of all permit approvals to the Engineer for the Engineer's records.

**110.19 Water Pollution Violations.** If a water pollution control violation exists on the Project which in the Engineer's judgment poses a public health or safety risk, such as a fuel or chemical spill or release of raw sewage, the Engineer shall refer the violation to the DNREC for immediate action. The cost of clean up shall be the sole responsibility of the Contractor if the DNREC investigation reveals the Contractor's actions caused the violation.

**110.20 Maintenance.** Erosion and sediment control items shall be maintained continuously throughout the duration of the project, including periods when the project is inactive or suspended. The Contractor shall repair, replace, or maintain any erosion and sediment control item promptly as noted on the E&S Report or as directed by the Site Reviewer or the Engineer. Any eroded surface shall be stabilized, and any accumulated sediment not trapped by a control measure shall be removed and disposed of in an approved stockpile area or hauled off-site. Access shall be maintained to all sediment control devices until construction phasing and stabilization allow the removal of those controls that are no longer required.

Costs associated with repairing, replacing, and maintaining the erosion and sediment control items are incidental to the initial construction of each item. Sediment removal will be paid for separately under Section 250.

**110.21 Erosion and Sediment Control Reports.** DelDOT will provide standard Erosion and Sediment Control Report forms and Stormwater Management Facility Construction Checklists to the Contractor to be used for all E&S Reports. The reports will itemize work required to maintain compliance with the Contract. The Contractor shall complete the items of work listed on or before the completion dates indicated on the reports.

**110.22 Failure to Implement and Maintain Erosion and Sediment Control Measures.** Controlling erosion and sedimentation is the Contractor's responsibility under the Contract. If the Contractor fails at any time to implement and maintain the required erosion and sediment control provisions of the Contract, fails to supply a Site Reviewer, or fails to routinely perform E&S inspections, complete the E & S Reports and correct deficiencies identified in the E & S Reports, the Engineer will notify the Contractor, orally or in writing, to comply with the required erosion and sediment control provisions. If the Contractor fails to perform the work as directed orally or in writing from the Engineer, the Engineer shall take any or all of the following actions listed below to gain compliance.

- A. *Limited Suspension of Activity.* The Engineer will order a "Limited Suspension of Activity" for the specific land disturbing activities that are not in compliance. Activities necessary to bring the site into compliance will be permitted. The Engineer will establish completion dates for the erosion and sediment control work. Time charges will continue during a Limited Suspension of Activity.
- B. *Withhold Progress Payment.* The Engineer may withhold monthly estimate and payment for all contract items.

C. *Stop Work Order.* The Engineer may suspend the performance of all construction, as noted in Subsection 105.02, until all items of work on the E & S Reports are complete and accepted.

Time charges will continue during this "Shut-Down" period and no claims for additional time or money shall be considered due to "Shut-Downs" resulting from the Contractor's failure to implement and maintain the required erosion and sediment control items.

D. *Deduct Cost of Work Completed By Others.* The Engineer may proceed with adequate forces and equipment of its own or a third party contractor to implement or maintain the erosion and sediment control items necessary to bring the Project into compliance with the Contract documents.

The entire cost to engage either a third party contractor or the Department's Maintenance personnel, including administration costs, will be deducted from monies due the Contractor.

E. *Default of Contract.* More than one "Shut-Down" for erosion and sediment control noncompliance may be considered as a failure to perform the terms of the Contract and will be grounds for finding the Contractor in default of the Contract in accordance with Subsection 108.10. If the Contractor defaults on the erosion and sediment control provisions of the Contract, the Project will be referred to the DNREC for enforcement action.

**110.23 Contractor Payment.** Payment will be made at the unit prices bid for the quantities of the various erosion and sediment control items provided in the Contract that are installed by the Contractor and accepted by the Engineer. Approved changes to the Erosion and Sediment Control Plans shall be paid at the applicable unit bid prices. Any additional work or corrections brought about as a result of errors by the Contractor, such as nonconformance with the Contract documents and the construction phasing, staging, or sequencing will be made at the Contractor's expense.

**110.24 Fines Resulting from Non-Compliance.** If the Department receives any fines from DNREC, the Army Corps of Engineers or the EPA as a direct result of the Contractor's refusal to implement and maintain the required erosion and sediment control, fails to supply a Site Reviewer, or fails to routinely perform E&S inspections, complete the E & S Reports and correct deficiencies identified in the E & S Reports, the Contractor will be responsible to pay the fines or the money will be deducted from monies due the contractor.

**Subsection 201.03 Trees and Roadside Amenities Designated to Remain.**  
**(5/15/2006)**

Modify the subsection title as shown above and modify the paragraph as follows:

The Engineer shall designate such trees, shrubbery, plants and roadside amenities, such as signs, light posts, or other improvements, which are not to be removed, and the Contractor shall protect them from any damage. If any such shrubbery, plants or roadside amenities are damaged, they shall be replaced or repaired. Any trees that are designated to remain that are damaged shall be evaluated by a certified tree surgeon and the contractor shall follow their recommendations to repair or for replacement of the trees. Branches of trees overhanging the roadbed shall be properly trimmed to maintain a clearance height of 20' (6 m), unless otherwise directed. All pruning shall be performed in accordance with the International Society of Arboriculture's Current Tree Pruning

Guidelines, Publication ISBN 1-881956-07-5, and as illustrated on the Standard Construction Details.

**Subsection 201.10 Basis of Payment. (5/15/2006)**

Modify the 1<sup>st</sup> paragraph as follows:

The quantity of clearing and grubbing will be paid for at the Contract lump sum. Price and payment will constitute full compensation for replacement of suitable material below required depth that was cleared and grubbed; for furnishing and compacting approved material to fill all depressions; for protecting trees, shrubbery, plants and other roadside amenities that are designated to remain, for replacement or repair of damaged trees, shrubbery, plants or other roadside amenities that are designated to remain; for disposal; and for all labor, equipment, tools, and incidentals required to complete the work.

**Subsection 207.03 Excavation. (1/3/2008)**

Add the following paragraph:

Shoring shall be provided for any excavation exceeding 5'-0" in height. The cost of shoring shall be incidental to item 207000 - Excavation and Backfill for Structures. In lieu of shoring, the contractor may cut slope back as allowed by soil conditions or other obstructions. No payment shall be made for additional excavation or fill outside of limits.

**Subsection 208.03 Excavation. (1/3/2008)**

Add the following paragraph:

Shoring shall be provided for any excavation exceeding 5'-0" in height. In lieu of shoring, the contractor may cut slope back as allowed by soil conditions or other obstructions. No payment shall be made for additional excavation or fill outside of limits.

**Subsection 209.02 General Requirements. (1/3/2008)**

Modify the 1<sup>st</sup> paragraph as follows:

The uses, classifications, characteristics, and definitions of terms for borrow materials shall be in accordance with the requirements of AASHTO M 57, Modified; M 145, Modified; and M 146 and M 147, Modified.

Unless otherwise directed, all materials having the following properties shall be excluded from use:

- (a) Material with a maximum dry weight less than 90lb/ft<sup>3</sup> (1440 kg/m<sup>3</sup>)
- (b) Material with a liquid limit greater than 40 or a plasticity index greater than 10.
- (c) Material containing any percentage of frozen material, rubbish, boulders in excess of 6" (150mm) in any direction, or an organic matter percentage greater than 2% (including leaves, roots, grass or sewage).

**Subsection 209.09 Method of Measurement. (1/3/2008)**

Modify the 3<sup>rd</sup> paragraph as follows:

Where the Engineer determines it to be impracticable to obtain weight-volume conversion factors for the borrow types specified, 3050 lbs of borrow will be considered equivalent to 1 yd<sup>3</sup>.

**Subsection 302.02 Materials. (5/15/2006)**

Modify the paragraph as follows:

The material used to construct graded aggregate base course shall conform to the requirements of Section 821. Crushed portland cement concrete may be used as graded aggregate base course, Type B, provided it conforms to the requirements of Section 821.

**Subsection 302.04 Placement. Subpart (c) Performance. (5/15/2006)**

Delete the first sentence in the 2<sup>nd</sup> paragraph as follows:

Compaction of graded aggregate Type B shall continue until each layer is thoroughly and uniformly compacted to 98% or more of the laboratory maximum density obtained on a sample of the same material. If the material is too coarse to use the test methods listed below, compaction shall continue until there is no movement of the material under the compaction equipment.

**Subsection 401.08 Placing Bituminous Mixtures. (1/3/2008)**

Add the following to the 2<sup>nd</sup> paragraph:

Type B Hot-Mix shall be placed in single individual lifts from 2.25" to 3" in depth.  
Type C Hot-Mix shall be placed in single individual lifts from 1.25" to 2" in depth.

**Subsection 401.09 Deep Lift Base Course. (1/3/2008)**

Modify paragraph (a) as follows:

The base course shall be placed with an approved paver or spreader in approximately equal layers of not less than 3" and not to exceed 6" in depth after compaction.

Add the following to paragraph (a):

When the contractor requests to use Type B Hot-Mix in lieu of BCBC, the Contractor shall request approval from the Engineer for this change. If approved by the Engineer, the Type B Hot-Mix may be placed in lifts of not less than 3" and not to exceed 6" in depth after compaction.

The Type B Hot-Mix placed in lieu of BCBC will be paid at the unit price for BCBC and the asphalt cement cost adjustment will be based on the virgin asphalt of BCBC, not the Type B Hot-Mix.

Modify paragraph (b) as follows:

Base course placed in irregular shaped areas of pavement, such as transitions, crossovers, and entrances, may be placed using a grader.

**Subsection 601.07 Hardware. (3/18/2004)**

Modify the first paragraph as follows:

Machine bolts, drift pins, dowels, nuts, washers, lag screws, and nails shall conform to the requirements of ASTM A307 Grade A.

Modify the first sentence of the second paragraph as follows:

Machine bolts shall have a hex head and nut, unless otherwise specified and shall conform to the requirements of ASTM A307, Grade A.

**Subsection 602.17 Finishing Concrete Surfaces, (b) Ordinary Surface Finish. (5/15/2006)**

Modify the 2<sup>nd</sup> sentence as follows:

On all surfaces, the cavities produced by form ties and all other holes, honeycomb spots, broken corners or edges, and other defects shall be thoroughly cleaned, saturated with water, and carefully pointed and trued with mortar mixed in the proportion of one part portland cement to three parts fine aggregate.

**Subsection 602.26 Method of Measurement. (Concrete Structures) (1/3/2008)**

Add the following sentence:

Haunches will be computed using the lesser of the designed dimensions or as-built dimensions.

**Subsection 612.05 Excavation. (3/18/2004)**

Delete the entire paragraph and insert the following:

The trench in which the pipe is laid shall be excavated to the required depth in accordance with Section 208 and the Standard Construction Details.

**Subsection 612.06 Bedding of Pipe. (3/18/2004)**

Delete the entire paragraph and insert the following:

Unless noted otherwise, all pipes shall receive a Class C bedding as shown on the Standard Construction Details.

**Subsection 612.11 Basis of Payment. (3/18/2004)**

Modify the second sentence of the first paragraph as follows:

Price and payment will constitute full compensation for furnishing, hauling, and installing pipe; for all cribbing or foundation treatment (Class C bedding) necessary to prevent settlement; for all shoring and sheeting; for the replacement of any pipe which is not true in alignment or which shows any settlement after laying; and for all material, labor, equipment, tools, and incidentals required to complete the work.

Modify the first sentence of the second paragraph as follows:

For round pipe under 24" (600 mm) nominal inside diameter, and elliptical pipe under 24" (600 mm) nominal inside horizontal dimension, the excavation (excluding rock), Class C bedding, backfill, and backfilling will be included in the price for this work.

Modify the last paragraph as follows:

Payment for excavation and replacement of unsuitable material encountered below the Class C bedding will be provided for under Section 208.

#### **Subsection 614.11 Basis of Payment. (3/18/2004)**

Modify the second sentence of the first paragraph as follows:

Price and payment will constitute full compensation for furnishing, hauling, and installing pipe; for all cribbing or foundation treatment (Class C bedding) necessary to prevent settlement; for all shoring and sheeting; for the replacement of any pipe which is not in true alignment or which shows any detrimental settlement after laying; for coating if required; and for all material, labor, equipment, tools, and incidentals required to complete the work.

Modify the first sentence of the second paragraph as follows:

For pipe under 24" (600 mm) nominal inside diameter and arch pipe under 24" (600 mm) nominal inside horizontal dimension, the excavation (excluding rock), Class C bedding, backfill, and backfilling will be included in the price of this work.

Modify the last paragraph as follows:

Payment for excavation and replacement of unsuitable material encountered below the Class C bedding will be provided for under Section 208.

#### **Subsection 617.02 Materials. (5/15/2006)**

Add the following sentence:

Reinforced concrete flared end sections shall be Class III for all types and class of pipes unless otherwise noted in the Plans.

#### **Subsection 619.11 Test Piles. (3/18/2004)**

In paragraph (a) (7) modify the second sentence as follows:

However, in no case shall the pile be driven to exceed 240 blows per 12" (300 mm) or 20 blows per 1" (25 mm) of driving for 3 consecutive inches (75 mm).

**Subsection 619.12 Driving Production Piles. (3/18/2004)**

In paragraph (5) modify the first sentence as follows:

In no case shall production piles be driven to exceed 240 blows per 12 inches (300 mm) or 20 blows per 1" (25 mm) for 3 consecutive inches (75 mm).

**Subsection 623.07 Non-Shrink Grout. (3/18/2004)**

Delete the entire paragraph and replace with the following:

Non-shrink grout shall conform to ASTM C1107, Grade C with one modification. The minimum 24-hour strength shall be increased to 5.0 KSI. The sampling and testing procedures of ASTM C1107 need not be changed.

**Subsection 623.11 Design Criteria. (1/3/2008)**

Modify the first paragraph as follows:

The design of the prestressed, precast, reinforced concrete members shall meet the requirements of the AASHTO LRFD Specifications for Highway Bridges.

The design load shall be HL 93.

**Section 701 - Curb and Integral Curb and Gutter (5/15/2006)**

Section 701 of the Standard Specifications is replaced with the following:

**701.01 Description.** This work consists of constructing curbs and integral curbs and gutters on a prepared foundation using either fixed forms or slip forms.

**MATERIALS.**

**701.02 Portland Cement Concrete.** Portland cement concrete shall conform to the requirements of Section 812, Class B for either fixed-form work or slip-form work.

**701.03 Liquid Membrane Curing Compounds.** Liquid membrane curing compound shall comply with Subsection 812.02 (i), (1) Curing Materials.

**701.04 Preformed Expansion Joint Material.** Preformed cork expansion joint material shall be 1/2" (13 mm) nominal thickness and conform to the requirements of Subsection 808.06.

**701.05 Bituminous Joint Sealant.** Bituminous joint sealant when needed for longitudinal joints as noted on C-1 and P-2 of the Standard Construction Details shall conform to the requirements of Subsection 808.04 (c).

**CONSTRUCTION METHODS.**

**701.06 Preparation of Foundation.** The foundation shall be prepared at the required grade to accommodate the elevations, dimensions, and details shown on the Plans. Grades shall be checked to ensure the drainage is adequate to prevent ponding. Existing subgrade shall be compacted until the surface is firm and unyielding. All unsuitable material shall be removed and replaced with approved material. Graded Aggregate Base Course Type B, (GABC) meeting the requirements of Subsection 302.02 shall be used unless otherwise directed. GABC shall be compacted with water as required in Subsection 302.04 except no spreader box will be required. Where rock is encountered, the grade shall be excavated to 6" (150 mm) below the bottom of the curb and integral curb and gutter and backfilled with GABC.

**701.07 Fixed Forms.** Fixed forms shall be of wood or metal and shall extend the full depth of the concrete. Composite material forms may be used for radii work. Forms shall be straight, free from warp greater than 1/8" in 10' (3 mm in 3 m), and of sufficient strength to resist the pressure of the concrete, and shall not displace more than 1/4" in 10' (3 mm in 3 m) from the vertical or horizontal plane. Forms shall remain in both horizontal and vertical alignment until their removal. Forms shall be clean and coated with an approved form release agent before concrete is placed. Divider plates shall be 1/8" thick metal.

**701.08 Slip-Forming.** Slip forming may be used provided that only approved equipment is used and the surface adjacent to the curb is firm and unyielding to support the weight of the machine.

**701.09 Placing Concrete.** The concrete shall be placed on a moist foundation, wetting the foundation if necessary. The concrete shall then be consolidated to eliminate air voids and worked sufficiently to bring mortar to the surface. The surface shall be struck off to the required contour and finished smooth and even with an approved float.

Limitations on placing concrete during hot or cold weather shall be as specified in Subsection 501.04.

**701.10 Joints.** Expansion joints shall be formed using templates or saw cut at no greater than 160' (49 m) intervals. Joints must be cut or formed vertically to the full depth of the curb to allow full contact of the expansion material with the entire surface. Additional expansion joints shall be constructed at each end of radii and at both sides of all structures or obstructions.

Contraction joints shall be constructed at 10' (3m) intervals. If not templated, all surfaces, front, top and back shall be tooled or saw cut to a minimum depth of 1" (25 mm) and a minimum width of 1/8" (3 mm). Saw cutting shall be done as soon as the concrete has sufficiently set or no more than 16 hours from the time of placement of the concrete to avoid shrinkage cracking. Any curb showing shrinkage cracks shall be removed and replaced at no cost to the Department.

When constructed adjacent to concrete pavement, joints shall coincide with joints in the pavement. When sidewalk is behind the curb all joints shall be in alignment and the expansion joints in the curb shall coincide with expansion joints in the sidewalk.

When curb is placed adjacent to Portland Cement Concrete pavement the curb or pavement shall be formed or tooled to allow sealing as shown in the Standard Construction Details C-1 and P-2.

**701.11 Finishing.** A wood or magnesium float shall be used to rub the surface smooth while the concrete is still green. Front and back edges of the curb shall be rounded to a 1/4 " (6 mm) radius. A steel trowel finish shall next be applied, and finally a soft dampened brush shall be used longitudinally along the surface. Finishing shall be performed to a depth of 2" (50 mm) below the proposed pavement surface elevation.

Before the concrete is given the final finish, the flow line of the gutter shall be checked to ensure positive drainage. Vertical alignment shall match adjacent surfaces such as curbs and drainage inlets. Any deviations in the flow line of more than 1/8" in 10' (3 mm in 3 m) shall be corrected. Irregularities in grade or alignment of the front and back edges of the curb shall not exceed 1/4" in 10' (6 mm in 3 m).

The ends of all curbs shall be transitioned to be flush with the pavement at a ratio of twelve to one (12:1). All approach and exit ends of median island and curb shall also be transitioned flush with the pavement at a ratio of twelve to one (12:1). Triangular (pork chop) island curb shall have all corners transitioned flush with pavement at a slope of four to one (4:1).

**701.12 Removal of Forms.** Forms may be removed as soon as concrete has hardened sufficiently. Fill all defects with mortar mixed in the proportion of one part portland cement to three parts fine aggregate.

**701.13 Curing.** Within 30 minutes of the completion of finishing to any portion of the concrete work and prior to any dehydration of the concrete surface, all exposed concrete surfaces shall be cured according to Section 501 for a period of no less than five days. The curb may be opened to traffic prior to the expiration of the five-day cure period if compressive strengths of the representative cores taken by the Department indicate that the strength of the concrete exceeds 2000 psi (14 Mpa). Any additional surfaces exposed prior to the expiration of the five-day cure period, by removing forms for example, shall be immediately cured to the same requirements for the remainder of the five-day period. Formwork that is allowed to remain in place and eliminate the need to cure the respective surfaces must remain tight against the surface to prevent drying of the concrete surface.

The application rate shall be not more than 200 ft<sup>2</sup>/gal (4.9 m<sup>2</sup>/L). During the curing period, pedestrian and vehicular traffic shall not disturb newly completed curb or integral curb and gutter other than as noted above.

**701.14 Method of Measurement.** The quantity of portland cement concrete curb and integral curb and gutter will be measured as the number of linear feet (linear meters) along the front face of the finished curb. Any curb showing cracks shall be replaced in sections that have a minimum length of 10' (3 m), at no cost to the Department.

**701.15 Basis of Payment.** The quantity of portland cement concrete curb and integral curb and gutter will be paid for at the Contract price per linear foot (linear meter). Price and payment will constitute full compensation for excavating (unless it is included in the excavation for the roadway box and paid for under Section 202), furnishing, and placing all materials; for forming, placing, finishing, and curing concrete; for backfilling, compacting, and disposing of surplus materials; for rounding curb edges, for sealing joints; and for all labor, equipment, tools, and incidentals required to complete the work. Grade Aggregate Base Course will be measured and paid for under Section 302. Isolated rock removal

shall be paid for under Section 206 unless already removed and included within Section 205.

**Subsection 705.09 Curing. (5/15/2006)**

Modify the sentence as follows:

Concrete shall be cured according to Section 501 for a period of 72 hours. The sidewalk shall not be opened to pedestrian traffic for 72 hours. Vehicular traffic shall not be permitted until after 5 days.

**Subsection 705.12 Basis of Payment. (5/15/2006)**

Add the following sentence:

Curb ramps constructed along the new P.C.C. sidewalk shall be incidental to the sidewalk item in this Section 705-Portland Cement Concrete Sidewalk.

**Subsection 708.05 – Frames. (3/18/2004)**

Add the following paragraph:

Frames for drainage grates fabricated from structural steel that meets or exceeds requirements of AASHTO M 270 Grade 36 or ASTM A 36 will also be acceptable. Such frames shall be fabricated from ½" (minimum thickness) stock, provide a 1 ¼" lip for support of the grate, have a 2" depth to accommodate a 2" thick grate, and have a bottom width of 4". Tolerances shall be + 1/8", -0". All cutting and welding shall be done in accordance with applicable portions of Subsection 826.12 by certified welders. The fabricated frame shall be hot dip galvanized in accordance with AASHTO M 111 (ASTM A 123) with a minimum of 2 ounces per square foot of zinc coating.

**Subsection 708.06 Gratings. (3/18/2004)**

Add the following paragraph:

Gratings for drainage inlets fabricated from structural steel that meets or exceed requirements of AASHTO M 270 or ASTM A 36 capable of HS-25 load rating will also be acceptable. Grates shall be of the Type 1, 2, or 3 style as shown in the Standard Construction Details. Type 1 shall have 1" x 2" perimeter bars. Type 2 and 3 shall have ¾" x 2" perimeter bars. Type 1, 2, and 3 shall have ½" x 2" internal bars. Grating spacers shall be flush with the top surface of the grate. Tolerances shall be + 1/8", -0". All cutting and welding shall be done in accordance with applicable portions of Subsection 812.12 by certified welders. The fabricated grate shall be hot dip galvanized in accordance with AASHTO M 111 (ASTM A 123) with a minimum of 2 ounces per square foot of zinc coating.

**Subsection 708.10 Precast and Cast-In-Place Drainage Inlets and Manholes. (5/15/2006)**

Modify the subsection title as shown above and modify the 1<sup>st</sup> paragraph as follows:

Precast and Cast-In-Place drainage inlets and manholes shall be constructed as shown on the Standard Construction Details. Cast-In-Place construction shall be used for drainage structures that tie into existing pipes and structures unless the Engineer approves the use of Precast. Shop drawings are not required for drainage inlets and manholes that match the Standard Construction Details. Shop drawing and design calculations, signed and sealed by a professional engineer, registered in the State of Delaware, shall be submitted for approval for all drainage structures that differ from the Standard Construction Details.

**Subsection 708.13 Inlet and Outlet Pipes. (5/15/2006)**

Modify the third sentence as follows:

Any space between the pipe and the walls of the drainage inlet shall be filled with non-shrink grout conforming to the requirements of ASTM C1107 with a strength of 5000 psi.

**Subsection 713.02 Stabilization. (1/3/2008)**

Modify the sentence as follows:

Geotextile for stabilization shall conform to the requirements of AASHTO M 288, Class 1, and Table 4.

**Subsection 713.03 Separation. (1/3/2008)**

Modify the sentence as follows:

Geotextile for separation shall conform to the requirements of AASHTO M 288 Class 2, and Table 3.

**Subsection 713.04 Erosion Control. (Modify title) (1/3/2008)**

Modify the sentence as follows:

Geotextile, woven monofilament for erosion control, shall conform to the requirements of AASHTO M 288, Class 2, and Table 5. All other non-woven geotextiles for erosion control, shall conform to AASHTO M 288 Class 1 and Table 5.

**Subsection 715.03 Perforated, Corrugated Polyethylene Tubing (CPT). (5/15/2006)**

Delete the entire paragraph and replace with the following:

Perforated, CPT shall conform to the requirements of AASHTO M252.

**Subsection 715.04 Stone. (3/18/2004)**

Modify the first sentence as follows:

Stone for backfill shall conform to the requirements of Section 813, Delaware No. 57.

**Subsection 715.05 Geotextile. (Modify Title) (1/3/2008)**

Modify the sentence as follows:

Geotextile shall conform to the requirements of AASHTO M 288 Class 2 or 3 and Table 2.

**Subsection 715.07 – Video Inspection. (3/18/2004)**

Delete the first sentence. Insert the following two sentences:

The entire underdrain system shall be videoed prior to the Project's final inspection. The Contractor may video the underdrain system prior to the placement of the final surface course over the area of the underdrain. If guardrail is placed within 3' (.9 m) from the underdrain, that section shall be videoed after installation of the guardrail.

**Section 720 Galvanized Steel Beam Guardrail. (5/15/2006)**

Change "Reflectorized Washers" to "Guardrail Reflectors".

**Subsection 720.05 Basis of Payment. (5/15/2006)**

After the third sentence, add the following sentences:

When specified in the Plans to place/replace or salvage individual elements of guardrail, and an item is listed for those items, then those individual components will be measured/paid as the number of each component under their respective bid item. When installing new guardrail, paid by the linear foot, these items are incidental to guardrail.

**Section 725 Guardrail-to-Barrier Connection (Approach and Exit Types). (5/15/2006)**

Change "Reflectorized Washers" to "Guardrail Reflectors".

**Section 726 Guardrail End Treatment. (5/15/2006)**

Change "Reflectorized Washers" to "Guardrail Reflectors".

**Subsection 732.02 Materials. (5/15/2006)**

Modify the third paragraph as follows:

Topsoil shall have an acidity range of pH 6.0 to pH 6.5. If necessary, lime shall be incorporated into the topsoil to raise the acidity or a sulfur-based product shall be

incorporated into the topsoil to lower the acidity. The rate shall be determined by the Engineer, and shall be accomplished prior to or at the time of seeding.

**Subsection 732.10 Basis of Payment. (5/15/2006)**

Modify the second sentence as follows:

Price and Payment will constitute full compensation for preparing the grade; for furnishing, hauling, and placing all materials, including necessary quantities of lime or sulfur; for maintaining topsoil, for loosening of the topsoil and subgrade to a total depth of 6" (150 mm); and for all labor, equipment, tools, and incidentals required to complete the work.

**Subsection 746.03 Construction Methods. (3/18/2004)**

Delete the last paragraph. Insert the following two sentences:

The concrete for pole bases shall be placed in accordance with the applicable requirements of Section 602. The bases shall be edged and have a broom finish.

**Subsection 748.09 Application. (5/15/2006)**

Add the following at the end of this subsection:

(f) *Removal of Pavement Markings when they are not properly applied.*

When it is necessary to remove pavement markings the following shall apply:

(1.) For paint and epoxy resin, shot/abrasive grit blasting or water blasting equipment shall be used.

(2.) For alkyd thermoplastic, in addition to the removal techniques discussed for paint and epoxy, burning or grinding equipment may be used.

The removal operation shall be performed in a manner that will not damage the pavement surface to a depth more than 1/8 inch. The contractor must satisfactorily demonstrate his/her proposed equipment and method of removal. Alternative equipment and methods will be considered if satisfactory results can be demonstrated.

The contractor shall collect and dispose of all shot/abrasive grit and pavement marking materials removed from the pavement surface. Washing or sweeping such materials to the roadside will not be permitted.

(3.) After removal of striping on bituminous concrete pavement, approved flat black paint or asphalt sealer shall be used to cover any exposed aggregate or embedded paint. Price and payment will also include payment for black paint or asphalt sealer.

**Subsection 760.04 Basis of Payment. (5/15/2006)**

Modify the paragraph as follows:

The quantity of pavement-milling will be paid for at the Contract unit price per square yard per inch of depth (square meter per 25 millimeters of depth) or at the Contract unit price per square yard (square meter). Price and payment will constitute full compensation for milling or planing the existing pavement; for the cleanup of the hot mix or concrete residue wedge left from the milling operation including but not limited to along the curb line, adjacent to speed humps, across intersecting streets, around manholes, and at the beginning and ending points of the milling operation, for removing and disposing of the milled material; and for all labor, tools, equipment, and incidentals required to complete the work.

**Subsection 808.02 Portland Cement Concrete Pavement. (5/15/2006)**

Modify Subpart (a) as follows:

a. *Hot-Poured Joint Sealant.* Hot-poured joint sealant shall conform to AASHTO M 324(Type-IV) or AASHTO M 282.

**Subsection 808.04 Portland Cement Concrete Structures. (5/15/2006)**

Modify Subpart (c) as follows:

c. *Bituminous Joint Sealant.* Bituminous joint sealants may be hot applied conforming to AASHTO M 324 Type-I, or cold applied elastomeric sealant conforming to Federal Specification SS-S-200E (2), Type H.

**Subsection 808.06 Portland Cement Concrete Curb and Integral Curb and Gutter. (5/15/2006)**

Modify the 1<sup>st</sup> Sentence as follows:

Materials for portland cement concrete curb and integral curb and gutter shall be preformed expansion joint material of ½" (13 mm) nominal thickness and shall conform to the requirements of AASHTO M 153, Type II.

**Subsection 812.04 Composition of Mix. (3/18/2004)**

Add the following to the notes under Table 812-A:

Note 13: Concrete (all classes), which fails to reach full 28 day design strength (fc') will be considered defective and will be evaluated in accordance with Subsection 602.25 Defective Work. Payment for the item with low strength concrete will be determined in accordance with Subsection 602.27 Basis of Payment (b) Price Adjustment for Low Strength Concrete.

Modify the statement in the bottom of box of Table 812-A as follows:

Notes 8, 9, 10, 11, and 13 refer to all classes of concrete. Note 12 refer to Class D concrete.

**Section 814 – Timber Preservatives. (3/18/2004)**

Delete Paragraph (a).

**Subsection 821.01 Description. (5/15/2006)**

Modify the paragraph as follows:

This material consists of coarse crushed stone, crushed slag fragments or portland cement concrete fragments. The Contractor shall certify that any recycled material, which is being proposed for use as graded aggregate, is neither hazardous nor toxic.

**Subsection 821.03 Material Details. (c) Gradation. (5/15/2006)**

Remove all references to graded aggregate, Type A (CR-1). Replace all of Subpart (c) Gradation with the following:

<b>WEIGHT PERCENT PASSING</b>	
<b>Sieve Size</b>	<b>% Passing</b>
	<b>Type B</b>
2 ½" (63.0 mm)	---
1 ½" (37.5 mm)	100
1" (25.0 mm)	---
¾" (19.0 mm)	50-95
No. 4 (4.75 mm)	20-50
No. 10 (2.00 mm)	15-40
No. 20 (850 um)	---
No. 100 (150 um)	2-20
No. 200 (75 um)	0-10

**Materials.** The graded aggregate shall meet the following properties:

<b>Property</b>	<b>Range</b>
Liquid Limit (T89) <sup>1</sup>	30 max
Plasticity Index (T90) <sup>1</sup>	4 max
Sand Equivalency <sup>1</sup>	25 min
Bituminous Concrete <sup>2</sup>	5% max
Brick <sup>2</sup>	5% max
Wood <sup>2</sup>	0.1% max
Metals <sup>2</sup>	0.1% max
Plaster <sup>2</sup>	0.1% max
Deleterious materials <sup>2</sup>	0.1% max
Los Angeles Abrasion	45% max

<sup>1</sup>Minus 0.425 mm (No. 40) sieve material

<sup>2</sup>By weight

Once a stockpile of material has been tested and approved, no material shall be added to it until the stockpile is depleted.

**Subsection 827.02 Silt Fence. (1/3/2008)**

Modify the last sentence as follows:

The geotextile shall be inert to commonly encountered chemicals and shall meet the requirements of AASHTO M 288 Table 6.

Delete Table 827-A

**Subsection 827.04 Inlet Sediment Control. (1/3/2008)**

Modify the entire paragraph as follows:

The geotextile for inlet sediment control shall conform to AASHTO M 288 Class 1 or 2 Table 5 for erosion control.

Delete Table 827-B

**Subsection 827.06 Riprap Ditch. (1/3/2008)**

Modify the entire paragraph as follows:

The geotextile for a riprap ditch shall conform to AASHTO M 288 Class 2 or 3 Table-2 for drainage.

**Subsection 827.12 Stabilized Construction Entrance. (1/3/2008)**

Modify the last sentence as follows:

The geotextile shall be inert to commonly encountered chemicals and hydrocarbons, be mildew and rot resistant, and shall conform to AASHTO M288 Class 1 and Table 4 for Traffic < 3 Axles and Class 1 and Table 4 for Traffic > 3 Axles

Delete Table 827-C

**Subsection 828.02 (f) Guardrail Reflectors. (5/15/2006)**

Change "Reflectorized Washers" to "Guardrail Reflectors".

Modify the paragraph as follows:

Guardrail reflectors shall be fabricated from steel sheet plates conforming to the requirements of ASTM A-6, galvanized to ASTM A153. Retroreflectorized sheeting shall be AR-1000 (Type V) Abrasive resistant and shall be applied in accordance with Subsection 720.03.